

To:

Mr. Richard Holmes, Principal, Chaires Elementary School

Ms. Brooks Sperling, Assistant Principal, Chaires Elementary

Mr. Ryan Peck, Director of Maintenance

Mr. Danny Allbritton, Director of Construction

From:

Mr. Tonnie Rollins, Project Manager, Fire & Safety Inspector Tul

Through:

Mr. LaRoderick E. McQueen, Certified Building Official/ Divisional Director

Date:

April 16, 2024

Subject:

SREF Inspection for Chaires Elementary School

Attached to this memorandum is the State Requirements for Educational Facilities (SREF) Inspection Report for the above referenced facility. The report identifies the deficiencies and corrective actions for the entire site. The column labeled MOC identifies the entity responsible for correcting each deficiency, as follows:

- Line items with an M (Maintenance) in the MOC column are to be addressed by the Maintenance Department. Please do not submit work orders for the deficiency line items in the M (Maintenance) column. Upon completion of all work orders, please have Code Enforcement staff sign off to confirm completion.
- Line items with an O (Operational) in the MOC column are to be addressed by site based staff. These items need to be corrected within the proposed time allotment, prior to the follow-up inspection.
- Line items with a C (Construction and Capital Outlay) in the MOC column are to be addressed by the Construction/Facilities Department or a corrective action plan developed.

Notification of the completion or corrective action plan of the fore-mentioned deficient items need to be submitted to the Code Enforcement Department. Please initial and date the line items under your area of responsibility on the provided report to confirm completion. You may email Ms. Katheryn White at whitek3@leonschools.net or fax the report to (850) 617-1790, to her attention.

Please note a copy of this SREF inspection report will be forwarded to the Board.

**Additionally, a separate inspection report has been provided for each portable at your site, in accordance with SREF Chapter 4
Section 4.4 (2**

**The SREF Inspection Reports for each individual portable on site are required by state to be posted. Please post the SREF Inspection Report in their respective portables in a visible location.

If you have any questions or comments regarding any items noted on this report, please feel free to contact Mr. Tonnie Rollins at the Code Enforcement Department at (850) 617-1800 or email at rollinst2@leonschools.net. Thank you for your time and cooperation in this matter.

ATTACHMENT

Cc: Ms. Anicia Robinson, Director of Elementary Schools (with attachments)

"Our Hands Keep Their Minds Working"

Code Enforcement, Compliance & Small Business Enterprise Department
3420 West Tharpe Street - Suite 100 - Tallahassee, Florida 32303-1138

(850) 617-1800 · Fax (850) 617-1790

https://www.leonschools.net/domain/6096

"The Leon County School District does not discriminate against any person on the basis of sex (including transgender status, gender nonconforming, and gender identity), marital status, sexual orientation, race, religion, ethnicity, national origin, age, color, pregnancy, disability, or genetic information."

02/29/2024

INSPECTION DATE

INSPECTOR: Tonnie Rollins

INSPECTOR SIGNATURE

SIGNATURE DATE

TYPE OF INSPECTION

SANITATION



FACITLITIES & CONSTRUCTION DEPARTMENT 3420 W. THARPE ST., TALLAHASSEE, FL 32303

COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2023 - 2024

Chaires Elementary School SCHOOL/ FACILITY/CAMPUS

4774 Chaires Crossroads

Tallahassee, Florida 32317

F.I.S.H. NUMBER

037-0491-049

					1100AL 1LAN, 2023 - 2024							
Item #	Building Number	Room Number	M O C	<u>Deficier</u>	ncy Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re- Inspection Correction Date	Site-Wide Building- Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT		
1	0000	000	О	Fall surfaces on	playground need to be raked and maintained regularly.	6			Site-Wide			
2	0000	000	0	Deodorizers, air	fresheners, scented oils, and plug-ins are not permitted by SREF.	6			Site-Wide			
3	0000	000	0	Gates around H	VAC equipment need to remain locked at all times.	7			Site-Wide			
4	0000	000	0	Fall surfaces are	needed in play areas.	1						
5	0000	000	0	All fire extinguis district.	shers need to be inspected monthly and card must be initialed and report sent to the	1						
6	0000	000	0	All mechanical g	gates shall remain locked at all times.	1				SREF5(2)(d)(3)		
7	0000	000	M	All water hoses	need to be on reels when not in use.	1						
8	0000	000	0	Freezer emergen	cy latch need to turn freely.	1						
9	0001	101A	0	Replace water st	rained and/or broken ceiling tile(s) (x1).	1						
10	0001	105	0	Replace water st	rained and/or broken ceiling tile(s) (x1).	1						
11	0001	106	0	Festive Lights sl	nall be temporary for 60 days.	2						
12	0001	106A	0	Room is not des	ignated storage on FISH report. Remove storage or add automatic initiation device.	1						
13	0001	112	0	Receptacle cove	r need to be replaced.	1						
14	0004	408	0	Remove combus	stible mateials hanging from ceiling.	1				NFPA 101-10.3.1		
15	0004	408A	О	Replace water st	tained and/or broken ceiling tile(s) (x1).	1						

Printed: 04/16/2024 - 10:08 AM

		02/29/	2024		LEON COUNTY SCHOOLS	Chaires Elementary School				
INSPE	CTION DA	ATE				SCHOOL/ FACILITY/CAMPUS				
INSPE	CTOR:	Tonnie i	Rollins			4774 Chaires Crossroads				
						Tallahassee, Florida 32317				
INSPEC	TOR SIGN	IATURE	SIGNA	TURE DATE	FACITLITIES & CONSTRUCTION DEPARTMENT					
	TY	PE OF IN	SPECTION	ON	3420 W. THARPE ST., TALLAHASSEE, FL 32303	F.I.S.H. NUMBER				
*	FIRE X	CASUAL	тү 🗱	SANITATION	COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2023 - 2024	037-0491-049				
Item #	Building Number	Room Number	M O C	<u>Deficier</u>	ncy Description and Corrective Action Required	# of Times Deficiency Previously Cited	Schedule for Correction No Later Than	Re- Inspection Correction Date	Site-Wide Building- Wide Exterior Campus or Portable	REMARKS CODE REFERENCE MAINTENANCE ASSIGNMENT
16	0004	412	О	Replace water st	ained and/or broken ceiling tile(s) (x5).	1				
17	0005	501	M	FISH number needs replacing.		1				Sign Shop
18	0005	501	0	Festive Lights sl	nall be temporary for 60 days.	1				
19	0005	501B	M	Light fixture nee	ed to be replaced.	1				Electrical Department
20	0005	501B	0	Replace water st	ained and/or broken ceiling tile(s).	1				
21	0005	504	М	Doors need to be properly adjusted.		1				Structural Department
22	0005	504A	0	Ramps coming of	off stage must remain clear at all times.	4				
23	0005	505D	M	Electrical junction boxes shall have all openings sealed.		1				Electrical Department NFPA 70-110.12(A)
24	0005	506A	0	Exercise emergency release on inside of freezer.		1				1
25	0007	702	0	Exit blocked		0				
26	0008	800	О	All electrical ou	tlets not in use are required to have plug coverings installed.	3				
27	0008	800A	0	Mechanical room	n used as storage	0				
					END OF SREF INSPECTION REPORT					
A re-in	spection of th	ne identified	deficiencie	es will be preformed	approximately days subsequent of inspection date.			IPara		

Printed: 04/16/2024 - 10:08 AM

02/29/2024		Chaires Elementary School						
INSPECTION DATE		SCHOOL/ FACILITY/CAMPUS						
INSPECTOR: Tonnie Rollins		4774 Chaires Crossroads						
	LEON COUNTY SCHOOLS	Tallahassee, Florida 32317						
INSPECTOR SIGNATURE SIGNATURE DATE	FACITLITIES & CONSTRUCTION DEPARTMENT							
TYPE OF INSPECTION	3420 W. THARPE ST., TALLAHASSEE, FL 32303	F.I.S.H. NUMBER						
FIRE CASUALTY SANITATION	COMPREHENSIVE SAFETY INSPECTION FISCAL YEAR: 2023 - 2024	037-0491-049						
Item Building Room Number O Deficier	ncy Description and Corrective Action Required	# of Times Deficiency Previously Cited Schedule for Correction No Later Than Site-Wide Building- Wide Exterior Campus or Portable Site-Wide Building- Wide CODE REFERENCE MAINTENANCE ASSIGNMENT						
The principal shall hold at least one (1) fire drill during each mo	nth, with an additional drill being held within the first 30 days of school.	NO						
Reviewed Emergency Generator Report. YES	NO Emergency Generator Report up-to-date as of SI	REF Inspection. YES NO						
Signature of facility administrator attesting to Fire Evacuation Drills and review of inspection report acknowledging awareness of discovered deficiencies:								

Leon County

School/Site Administrator